

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

November 15, 2019 to December 13,2019

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A	327,536
Control B	168,743

TOTAL PURCHASED WATER

Trucked – 0

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Have been working with Tim from Dana Kipler and Adam Fedler on completing the import information for the route file for the new metering system.
- 3) I anticipate the route file being completed by this month's billing.
- 4) We have had a number of customers with concerns about their usage after the new meters have been installed. This was expected, with the old and less accurate meters being replaced with the new highly accurate meters.
- 5) Some homes have had from a 10% to 25% and higher usage. So I started Bucket test for those customers who have requested one.
- 6) The new meters have all been certified from the factory as with in the American Water Works Association standards of 98.5% to 100% accuracy.

OTHER BUSINESS:

Freezing night time temps are here. Please disconnect any outside hoses from your house to prevent damage to your plumbing.

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.