

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

December 13, 2018 to January 11, 2019

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A	413,880
Control B	128,582

TOTAL PURCHASED WATER

Trucked – 35

(Amount received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Replaced Chemical pump at control B
- 3) GWUDI testing has been completed and results have been posted on the AAMD website.
- 4) We had a water line brake which caused a water emergency and water was trucked in to keep the system running. The leak was found and isolated and now the system is running off of our wells with no further hauled water.
- 5) Spoke to the CDPHE Compliance department about anonymous phone calls concerning false accusations. The results of my conversation is posted on the website.

OTHER BUSINESS:

Freezing temps are here. Remember that you get one service turn on and one turn off for vacation or a period of time when your home maybe vacant.

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.