

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

March 14, 2020 to April 8, 2020

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A 371,458

Control B 181,743

TOTAL PURCHASED WATER

Trucked – 0

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Replaced meter on Salbani.
- 3) Performed quarterly tank inspection per state “Storage Tank Rule”.
- 4) Attended via phone covid-19 conference by EPA for water systems, 4-1-20 and 4-7-20
- 5) Negotiated ORC contract with Kevin Walker WSDM
- 6) Flush Hydrant at the end of Gerka and the one at 222 Denwood, needs to be replaced this spring.
- 7) Covid-19 update. The CDC, CDHEP, and the EPA, have all determined that that since the virus can only live in water for a very short period of time, and is not present in ground water. That the standard water disinfection practices are sufficient to kill this and all other viruses for potable water.

OTHER BUSINESS:

Freezing night time temps are still here. Please disconnect any outside hoses from your house to prevent damage to your plumbing.

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.