

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

June 4, 2020 to July 6, 2020

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A

Control B

TOTAL PURCHASED WATER

Trucked – 11

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Filters for control B arrived started changing filter at B to help with turbidity.
- 3) Well #6 is not pumping to its capacity, it could be lack of water in well or something with the pump.. Black Mt Pump came out and examined, results will be updated. .
- 4) Read, recorded and turned in meter reads.
- 5) Mainline on Deer ridge was broken by contractor.
- 6) Started marking and locating all vales with Mike from Aqua Works.
- 7) Mike and I are doing a total pumping analysis on all wells and the control buildings to see if we may have a leak in the raw water feeder lines going to the control buildings.
- 8) Wells are not keeping up with demand, that is why we are doing number 7.
- 9) Covid-19 update. The CDC, CDHEP, and the EPA, have all determined that that since the virus can only live in water for a very short period of time, and is not present in ground water. That the standard water disinfection practices are sufficient to kill this and all other viruses for potable water.

OTHER BUSINESS: