

# **ARABIAN ACRES METROPOLITAN DISTRICT**

## **MONTHLY OPERATIONS REPORT**

**July 12, 2019 to August 16,2019**

**Submitted by: Lynn Willow, O.R.C/Operator**

### **TOTAL WATER PUMPED**

**Control A            451,719**

**Control B            32,924**

### **TOTAL PURCHASED WATER**

**Trucked – 0**

**(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)**

### **OPERATIONS & MAINTENANCE ISSUES**

- 1) Bac-T samples for the month have been taken and are negative.
- 2) No leaks this month.
- 3) Meter Project is coming along good. Contractors are getting ready to install the Well meter pits.
- 4) Mainline flushing and hydrant exercising almost completed.
- 5) No major issues with the system.

### **OTHER BUSINESS:**

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.