

# **ARABIAN ACRES METROPOLITAN DISTRICT**

## **MONTHLY OPERATIONS REPORT**

**August 17,2019 to September 11, 2019**

**Submitted by: Lynn Willow, O.R.C/Operator**

### **TOTAL WATER PUMPED**

<b>Control A</b>	<b>447,371</b>
<b>Control B</b>	<b>92,384</b>

### **TOTAL PURCHASED WATER**

**Trucked – 4**

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

### **OPERATIONS & MAINTENANCE ISSUES**

- 1) Bac-T samples for the month have been taken and are negative.
- 2) 4 loads of water was brought in due to lightning and electrical issues with wells 6 and 7.
- 3) No leaks this month.
- 4) Meter Project is coming along good. Contractors have installed the Well meter pits.
- 5) Meter Project should be completed by the end of the month.

### **OTHER BUSINESS:**

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.