

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

September 11, 2019 to October 9, 2019

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A 378,151

Control B 87,632

TOTAL PURCHASED WATER

Trucked – 0

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) All of the new meter pits are installed with the acceptance of one.
- 3) Black Mt. Pump replaced the pump at well #4. It went out this month, it was installed in 1996. They also put in a bigger pump to match the pump curve.
- 4) Drive by meter reading will start the week of 10-14. We will start working out any bugs before the end of the month final read.
- 5) Annual lead and copper testing was completed and the system results were above the max. allowable amount for lead in two samples by .03 MGL. What this means is I will have to do extra testing for the next six months.

OTHER BUSINESS:

Freezing night time temps are here. Please disconnect any outside hoses from your house to prevent damage to your plumbing.

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.

