

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT for period: March 11, 2017 to April 10, 2017

Submitted by: Lynn Willow, Operator/O.R.C.

TOTAL WELL PRODUCTION

Control Building –A: 392907 gallons

Control Building – B: 28,441 gallons

TOTAL PURCHASED WATER

Trucked – 0 loads

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- Bac-T samples for the month have been taken and are negative.
- I have started my annual exercise of the Hydrants. I will do 3 a month as not to disrupt the tank
- Level.
- I had a power outage on 4/5/17 from Spring storm at control A, went up to district and restored
- Power.
- Well # 3 is off line and on stand-by, for turbidity reasons (Cloudy water).
- If well# 3 is needed I will put it back on line
- Requesting the board approve \$432.00 for a new Chlorine Colorimeter for the district. The one ✓
- we have is over 12 years old and is not that accurate any more, and was suggested by the state
- to replace.
- System is working well at this time with no apparent leaks.

OTHER BUSINESS;

Winter is not over yet! All residents should check their home's for proper piping insulation and leave your cabinet doors open under your sinks at night to prevent freezing.

Remember, all customers get one free water service turn on and turn off for the year.