

# ARABIAN ACRES METROPOLITAN DISTRICT

## MONTHLY OPERATIONS REPORT

March 15, 2018 to April 13, 2018

Submitted by: Lynn Willow, O.R.C/Operator

### TOTAL WELL PRODUCTION

Control Building –A: 421,611 gallons

Control Building – B: 61,075 gallons

### TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

### OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Garvin Brown, Surface water Commissioner and I are trying to set up meeting for the week of 4-16-18 to inspect AAMD pond #2.
- 3) I have started the GWUDI testing for the state again to complete by 2018,
- 4) It will consist of temp. and conductivity testing at 2 to 4 locations 2 times per week until October. And 1 MPA at each well in June-July.
- 5) Keeping a close eye on the district, for possible water line leaks due to spring thawing. This is the time of year that hidden leaks can appear.
- 6) Customers need to contact me directly through phone call or email (both are on AAMD web site) if they have a concerns about water issues.

### OTHER BUSINESS:

Freezing problems are still possible, Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.