

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT for period: July 14, 2017 to August 10, 2017

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building –A: 435,135 gallons

Control Building – B: 10,320 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative. ✓
- 2) Valve exercise is completed. ✓
- 3) Finished up dating O & M manual. ✓
- 4) Browns Hill has been on site working on Mission Tank Leveler. As we were making repairs there was more damage than first diagnosed. ✓
- 5) Transducer was also damaged and also the radio antenna (the total tank level system) was replaced. ✓
- 6) Judy has been informed of the updated damage and is working with the insurance co. ✓
- 7) State compliance testing is going on this month (lead and copper, TTHM's, and HAA5's). ✓

OTHER BUSINESS:

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.