

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

July 19, 2018 to August 10, 2018

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL PURCHASED WATER

Trucked – 4

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Black Mt. Pump was out to work on well #2. Come to find out it is a communication issue so, I called our SCAD contractor.
- 3) Browns Hill engineering was out to work on SCADA to find out why we are having so many problems with Well's 2 and 8. It is possible that we have a bad power source to the wells. A radio operated well system for those two well maybe a better solution. The cost would be a lot less then treaching another electric line to the wells.
- 4) Well # 1 has been giving us a problem, so Black Mt. pump was out on 8-10-2018 to pull the well and see what the problem is (maybe a pump change out).

OTHER BUSINESS:

Hydrant and valve exercising are in process.