

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

November 11, 2017 to December 12, 2017

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building –A: 389,981 gallons

Control Building – B: 19,529 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Tank Circulator installation is completed and is doing what it is supposed to be doing. Water is moving good and no ice in tank.
- 3) I had Adam help me with the trenching and hook up.
- 4) Replaced meter at home on DenWood Dr.
- 5) Trout Heaven has shut down and winterized for the winter.
- 6) Replaced battery on mission.

OTHER BUSINESS:

Winter is here. Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.