

# ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT for period: December 21, 2016 to Jan. 12, 2017

Submitted by: Lynn Willow, Operator/O.R.C.

## TOTAL WELL PRODUCTION

Control Building – A: 333,572 gallons

Control Building – B: 122,229 gallons

## TOTAL PURCHASED WATER

Trucked – 0 loads

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

## OPERATIONS & MAINTENANCE ISSUES

- Bac-T samples for the month have been taken and are negative. ✓
- Meters have been read and recorded. ✓
- Ice has formed in tank (1.5 feet in thickness), this accrues every year. ✓
- Ice forming has complicated tank set points to some degree. ✓
- I am looking into the cost of a tank water circulator to stop ice buildup in tank. ✓
- System is working well at this time with no leaks. ✓

## OTHER BUSINESS:

Winter is here! All residents should check their home's for proper piping insulation and leave your cabinet doors open under your sinks at night to prevent freezing.

Remember, all customers get one free water service turn on and turn off for the year.