

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

December 13, 2017- January 10, 2018

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building – A: 409,096 gallons

Control Building – B: 61,167 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Training with Adam. Valve locating and meter reading.
- 3) Turned water service off on one resident for lack of payment. As of this date still no payment has been made.
- 4) Have been in contact with Adam from Aqua Works in regards to system inventory and future projects.
- 5) I heard of complaints of chlorine smell in some customer's tap water. I did some extra cl2 testing throughout the system and made adjustments to the dosing rate. I have not heard of any complaints since.
- 6) Customers need to contact me directly through phone call or email (both are on AAMD web site) if they have a concerns about water issues.

OTHER BUSINESS:

Winter is here. Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

December 13, 2017- January 10, 2018

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building –A: 409,096 gallons

Control Building – B: 61,167 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Training with Adam. Valve locating and meter reading.
- 3) Turned water service off on one resident for lack of payment. As of this date still no payment has been made.
- 4) Have been in contact with Adam from Aqua Works in regards to system inventory and future projects.
- 5) I heard of complaints of chlorine smell in some customer's tap water. I did some extra cl2 testing throughout the system and made adjustments to the dosing rate. I have not heard of any complaints since.
- 6) Customers need to contact me directly through phone call or email (both are on AAMD web site) if they have a concerns about water issues.

OTHER BUSINESS:

Winter is here. Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.