

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT for period: May 12, 2017 to June 16, 2017

Submitted by: Lynn Willow, Operator/O.R.C.

TOTAL WELL PRODUCTION

Control Building – A: 430,172 gallons

Control Building – B: 5,825 gallons

TOTAL PURCHASED WATER

Trucked – 0 loads

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- Bac-T samples for the month have been taken and are negative.
- Tip Top Tree was out and completed mitigation work at contracted price.
- Still working annual exercise of the Hydrants.
- Still working the annual valve exercise.
- Turned water on at 386 Gerka for inspection. Home had leak in crawl space just past water filter.
- Working on O&M manual.
- Waiting to get scheduled for prairie dog extermination.
- System is working well at this time with no apparent leaks.

OTHER BUSINESS;

Working with Judy and Clay Brown on grant information.

Remember, all customers get one free water service turn on and turn off for the year.