

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

February 15, 2019 to March 15, 2019

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WATER PUMPED

Control A 402,010

Control B 105,112

TOTAL PURCHASED WATER

Trucked - 15

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Leak found and repaired on Denwood.
- 3) Two frozen service lines thawed on Kutsu Ridge Rd.
- 4) Ordered and installed new Chemical pump for Control Building A
- 5) Pre-bid meeting with contractors, engineer, and hydrologist.
- 6) Browns Hill Engineering was out to install new radio and Battery for tank level.

OTHER BUSINESS:

Freezing temps are here. Remember that you get one service turn on and one turn off for vacation or a period of time when your home maybe vacant.

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions regarding water treatment and distribution.