

# ARABIAN ACRES METROPOLITAN DISTRICT

## MONTHLY OPERATIONS REPORT

April 15, 2018 to May 10, 2018

Submitted by: Lynn Willow, O.R.C/Operator

### TOTAL WELL PRODUCTION

Control Building –A: 415,925 gallons

Control Building – B: 170,260 gallons

### TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

### OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Meters have been read and recorded.
- 3) Prairie Dog mitigation will begin 4-11-2018
- 4) Garvin Brown, Surface water Commissioner has not got back with me as of yet.
- 5) I have started the GWUDI testing for the state again to complete by 2018,
- 6) I put out 4 48 hr. notices.
- 7) Customers need to contact me directly through phone call or email (both are on AAMD web site) if they have a concerns about water issues.

### OTHER BUSINESS:

Freezing problems are still possible, Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.