

ARABIAN ACRES METROPOLITAN DISTRICT

MONTHLY OPERATIONS REPORT

October 11, 2017 to November 11, 2017

Submitted by: Lynn Willow, O.R.C/Operator

TOTAL WELL PRODUCTION

Control Building – A: 402,928 gallons

Control Building – B: 14,705 gallons

TOTAL PURCHASED WATER

Trucked – 0

(amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

OPERATIONS & MAINTENANCE ISSUES

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Meters have been read and recorded.
- 3) Tank Circulator has been purchased and installed in storage tank.
- 4) President Winters and I met with Mr. Rupp at AAMD pond number two, to inspect and discuss with Mr. Rupp about releasing pound water for augmentation.
- 5) A service tap was installed in mid October.

OTHER BUSINESS:

Winter is here. Please check your plumbing for proper installation.

If anyone has questions about protecting your water lines, please call Lynn Willow.

Remember you get one free turn-off and turn-on per year.

Please contact me at 719-482-5125 about any vacant homes in your area.