

# **ARABIAN ACRES METROPOLITAN**

## **DISTRICT**

### **MONTHLY OPERATIONS REPORT**

**August 10, 2018 to September 11, 2018**

**Submitted by: Lynn Willow, O.R.C/Operator**

#### **TOTAL PURCHASED WATER**

**Trucked – 0**

(Amount actually received per each 4,000 gallon load is generally 200-300 gallons less due to standard and typical hauling losses)

#### **OPERATIONS & MAINTENANCE ISSUES**

- 1) Bac-T samples for the month have been taken and are negative.
- 2) Well # 2 and Well # 1 are running at capacity since the repairs were made last month.
- 3) Browns Hill engineering was out to replace SCADA radio for Mission Communication, and it has improved the communication link by 30%.
- 4) Testing for state compliance continues.

#### **OTHER BUSINESS:**

Winter is coming soon. Remember that you get one service turn on and one turn off for vacation or a period of time when your home maybe vacant.

There has been a rumor of AAMD water being unsafe. This is completely untrue, and in my opinion, this is a slanderous statement with no merit. The State CDHEP water quality control director has been in contact with me, and has reviewed our water quality from 2002 to present. And AAMD has not had a single water quality issue since the district was established. There was one failed Bac.-T test in 2010, but after extensive retesting the results were negative and found safe.

All of our water quality records are located at the state and each customer receives a CCR (Consumer Confidence Report) after June 30<sup>th</sup> of each year. Please read the next CCR that you receive in the mail so that you can get an understanding of how things work (aganirsen is Bless).

I will stay after each BOD meeting (when I can) for a short period of time to answer any questions.