



**Lead and Copper Certified Laboratory Report Form**  
**Submit Online: [wqcdcompliance.com/login](http://wqcdcompliance.com/login) (preferred); Fax (303) 758-1398**  
**WQCD-B2-Drinking Water CAS**  
**4300 Cherry Creek Drive South; Denver, CO 80246-1530**

**LCR - Results**

Revision: 11/01/2016

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)			
Public Water System Information				Certified Laboratory Information			
PWSID#: CO0160075		Facility ID: DS001		Laboratory ID: CO015			
System Name: Arabian Acres Metro District				Laboratory Name: Colorado Analytical Laboratory			
Contact Person: Lynn Willow		Phone #: 303-704-9438		Contact Person: Customer Service		Phone: 303-659-2313	
Comments:				Comments:			

Section III (Supplied or Completed by Public Water System)				Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
3/9/21	Homeowners	LCR011	LC-1	3/22/21	3/23/21	210322006-01	Copper	EPA 200.8	1.3	0.001	<b>0.018</b>
							Lead	EPA 200.8	0.015	0.001	<b>0.003</b>
3/9/21	Homeowners	LCR012	LC-2	3/22/21	3/23/21	210322006-02	Copper	EPA 200.8	1.3	0.001	<b>0.004</b>
							Lead	EPA 200.8	0.015	0.001	<b>0.002</b>
3/9/21	Homeowners	LCR001	LC-3	3/22/21	3/23/21	210322006-03	Copper	EPA 200.8	1.3	0.001	<b>0.008</b>
							Lead	EPA 200.8	0.015	0.001	<b>0.002</b>
3/9/21	Homeowners	LCR013	LC-4	3/22/21	3/23/21	210322006-04	Copper	EPA 200.8	1.3	0.001	<b>0.003</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>
3/9/21	Homeowners	LCR005	LC-5	3/22/21	3/23/21	210322006-05	Copper	EPA 200.8	1.3	0.001	<b>0.011</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>

NT: Not Tested  
 Lab MRL: Laboratory Minimum Reporting Level  
 BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter  
 AL: Action Level

210322006 Y

1/2

Sample Date	Collector	Sample Pt ID	Address, City, Zip	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	AL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
3/9/21	Homeowners	LCR014	LC-6	3/22/21	3/23/21	210322006-06	Copper	EPA 200.8	1.3	0.001	<b>0.003</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>
3/9/21	Homeowners	LCR015	LC-7	3/22/21	3/23/21	210322006-07	Copper	EPA 200.8	1.3	0.001	<b>0.007</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>
3/9/21	Homeowners	LCR016	LC-8	3/22/21	3/23/21	210322006-08	Copper	EPA 200.8	1.3	0.001	<b>0.006</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>
3/9/21	Homeowners	LCR017	LC-9	3/22/21	3/23/21	210322006-09	Copper	EPA 200.8	1.3	0.001	<b>0.003</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>
3/9/21	Homeowners	LCR018	LC-10	3/22/21	3/23/21	210322006-10	Copper	EPA 200.8	1.3	0.001	<b>0.005</b>
							Lead	EPA 200.8	0.015	0.001	<b>BDL</b>

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter

AL: Action Level

# Drinking Water Chain of Custody



<b>Report To Information</b>	<b>Bill To Information (If different from report to)</b>	<b>Project Information</b>
Company Name: <u>Arabam Acres MD</u>	Company Name: <u>Arabam Acres</u>	PWSID: <u>CO 0160075</u>
Contact Name: <u>Lynn Willow</u>	Contact Name: <u>Rebecca Hordelope</u>	System Name: <u>Arabam Acres</u>
Address: <u>5305 whimsical DR</u>	Address: <u>614 N Tejon ST</u>	Compliance Samples: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
City: <u>C/S</u> State: <u>CO</u> Zip: <u>80917</u>	City: <u>C/S</u> State: <u>CO</u> Zip: <u>80903</u>	Send Results to CDPHE: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Phone: <u>719 482 5125</u>	Phone: <u>719 447-1777</u>	Task Number (Lab Use Only): <b>CAL Task</b> <b>210322006</b>
Email: <u>LYWLL9@AOL.COM</u>	Email: <u>rebecca.h@coloradodisfor.c13.co</u>	<b>JML</b>
Sample Collector: <u>Home Owners</u>	PO Number: <u>Lead + Copper</u>	

**Commerce City Lab**  
10411 Heinz Way  
Commerce City CO 80640

**Lakewood Service Center**  
12860 W. Cedar Dr, Suite 100A  
Lakewood CO 80228

Phone: 303-659-2313

[www.coloradolab.com](http://www.coloradolab.com)

PHASE I, II, V Drinking Water Analyses (check requested analysis)													Subcontract Analyses																	
Date	Time	Client Sample ID / Sample Pt ID	No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorite	
3-9-21	6:45	LC-1															X													
3-9-21	8:30	LC-2															X													
3-9-21	6:05	LC-3															X													
3-9-21	5:45	LC-4															X													
3-9-21	7:00	LC-5															X													
3-9-21	7:30	LC-6															X													
3-9-21	6:50	LC-7															X													
3-9-21	7:25	LC-8															X													
3-9-21	8:10	LC-9															X													
3-9-21	7:15	LC-10															X													

**Instructions:** 10

**C/S Info:** Delivered Via: UPS C/S Charge  Temp: 14°C / Ice N Sample Pres. Yes  No

Seals Present Yes  No  Headspace Yes  No

Relinquished By:	Date/Time:	Received By:	Date/Time:	Relinquished By:	Date/Time:	Received By:	Date/Time:
<u>Lynn Willow</u>	<u>3/19/21</u>	<u>Adama</u>	<u>3/22/21</u>				