

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-1
Sample Date/Time: 10/1/21 6:30 AM
Lab Number: 211007068-01

Sample Point ID: LCR001

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	BDL	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-2

Sample Date/Time: 10/1/21 6:45 AM

Sample Point ID: LCR002

Lab Number: 211007068-02

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.002	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-3

Sample Date/Time: 10/1/21 6:30 AM

Sample Point ID: LCR003

Lab Number: 211007068-03

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	BDL	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-4

Sample Date/Time: 10/1/21 7:10 AM

Sample Point ID: LCR004

Lab Number: 211007068-04

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.001	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-5

Sample Date/Time: 10/1/21 7:15 AM

Sample Point ID: LCR005

Lab Number: 211007068-05

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	BDL	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-6

Sample Date/Time: 10/1/21 8:00 AM

Sample Point ID: LCR006

Lab Number: 211007068-06

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.001	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow

Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-7

Sample Date/Time: 10/1/21 5:20 AM

Sample Point ID: LCR007

Lab Number: 211007068-07

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.001	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-8

Sample Date/Time: 10/1/21 7:00 AM

Sample Point ID: LCR008

Lab Number: 211007068-08

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.001	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-9

Sample Date/Time: 10/1/21 7:00 AM
Lab Number: 211007068-09

Sample Point ID: LCR009

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.001	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Report To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Bill To: Lynn Willow
Company: Arabian Acres Metro District
614 N. Tejon St
Colorado Springs CO 80903

Task No.: 211007068
Client PO: L&C
Client Project: Arabian Acres Metro District CO0160075

Date Received: 10/7/21
Date Reported: 10/15/21
Matrix: Water - Drinking

Customer Sample ID LC-10

Sample Date/Time: 10/1/21 8:15 AM

Sample Point ID: LCR010

Lab Number: 211007068-10

Test	Result	Method	RL	MCL	Date Analyzed	QC Batch ID	Analyzed By
<i>Total</i>							
Copper (mg/L)	0.002	EPA 200.8	0.001	1.3	10/12/21	QC52698	MBN
Lead (mg/L)	BDL	EPA 200.8	0.001	0.015	10/12/21	QC52698	MBN

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
mg/L = Milligrams Per Liter or PPM
ug/L = Micrograms Per Liter or PPB
mpn/100 mls = Most Probable Number Index/ 100 mls
Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
(s) Spike amount low relative to the sample amount.
BDL = Not Detected at Reporting Limit.

Analytical QC Summary

TASK NO: 211007068

Report To: Lynn Willow
Company: Arabian Acres Metro District

Receive Date: 10/7/21
Project Name: Arabian Acres Metro District CO0160075

Test	QC Batch ID	QC Type	Result	Method		
Copper	QC52698	Method Blank	ND	EPA 200.8		
Lead	QC52698	Method Blank	ND	EPA 200.8		

Test	QC Batch ID	QC Type	Limits	% Rec	RPD	Method
Copper	QC52698	LCS	90 - 110	92.3	-	EPA 200.8
		MS	70 - 130	99.5	-	
		MSD	0 - 10	-	2.1	
Lead	QC52698	LCS	90 - 110	97.8	-	EPA 200.8
		MS	70 - 130	93.8	-	
		MSD	0 - 10	-	0.4	

All analyses were performed in accordance with approved methods under the latest revision to 40 CFR Part 136 unless otherwise identified. Based on my inquiry of the person or persons directly responsible for analyzing the wastewater samples and generating the report (s), the analyses, report, and information submitted are, to the best of my knowledge and belief, true, accurate, and complete.



DATA APPROVED FOR RELEASE BY

Abbreviations/ References:

RL = Reporting Limit = Minimum Level
 mg/L = Milligrams Per Liter or PPM
 ug/L = Micrograms Per Liter or PPB
 mpn/100 mls = Most Probable Number Index/ 100 mls
 Date Analyzed = Date Test Completed

(d) RPD acceptable due to low duplicate and sample concentrations.
 (s) Spike amount low relative to the sample amount.
 BDL = Not Detected at Reporting Limit.

Drinking Water Chain of Custody



LABORATORIES, INC.

Commerce City Lab
10411 Heinz Way
Commerce City CO 80640

Lakewood Service Center
12860 W. Cedar Dr, Suite 100A
Lakewood CO 80228

Phone: 303-659-2313

www.coloradolab.com

Report To Information		Bill To Information (if different from report to)		Project Information	
Company Name: <u>Asheburn Acres MO</u>	Company Name: <u>Arabian Acres</u>	PWSID: <u>6160075</u>		System Name: <u>Arabian Acres MO</u>	
Contact Name: <u>Ann Willow</u>	Contact Name: <u>Rebecca</u>	Compliance Samples: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		Send Results to CDPHE: Yes <input type="checkbox"/> No <input type="checkbox"/>	
Address: <u>5305 Schumical DR</u>	Address: <u>614 N Tejon ST</u>	Task Number (Lab Use Only)		CAL Task	
City: <u>CO</u> State: <u>CO</u> Zip: <u>80917</u>	City: <u>CO</u> State: <u>CO</u> Zip: <u>80903</u>	PO Number: <u>211007068</u>		EMN	
Phone: <u>719 482 5125</u>	Phone: <u>719 447 1777</u>	Email: <u>rebecca.h@sdsdisto.com</u>			
Email: <u>AnnWillow@AOL.com</u>					
Sample Collector: <u>Dawn</u>					
Sample Collector Phone: <u>Same</u>					

Date		Time		Client Sample ID / Sample Pt ID		No. of Containers	Residual Chlorine (mg/L) P/A Samples Only	Total Coliform P/A	504.1 EDB/DBCP	505 Pests/PCBs	515.4 Herbicides	524.2 VOCs	525.2 SOCs-Pest	531.1 Carbamates	547 Glyphosate	548.1 Endothall	549.2 Diquat	524.2 TTHMs	552.2 HAA5s	Lead/Copper	Nitrate	Nitrite	Fluoride	Inorganics	Alk./Lang. Index (Circle)	TOC, DOC (Circle)	SUVA, UV 254 (Circle)	Gross Alpha/Beta	Radium 226/228	Radon	Uranium	Chlorine		
10-1		6:30		LC-1		1																												
10-1		6:45		LC-2		1																												
10-1		6:30		LC-3		1																												
10-1		7:16		LC-4		1																												
10-1		7:15		LC-5		1																												
10-1		8:18		LC-6		1																												
10-1		5:20		LC-7		1																												
10-1		7:00		LC-8		1																												
10-1		7:00		LC-9		1																												
10-1		8:15		LC-10		1																												

PHASE I, II, V Drinking Water Analyses (check requested analysis)

Subcontract Analyses

Instructions: (10)

Relinquished By: [Signature] Date/Time: 10-6-21

Received By: [Signature] Date/Time: 10/7/21

Delivered Via: WRS Relinquished By: [Signature]

C/S Charge Date/Time: 10/7/21

Temp: 20 °C/ice N

Seals Present Yes No Headspace Yes No

Sample Pres. Yes No